

[illegible]

NOMBRE: TAA BARRAS: 1200A VOLTAJE : 277/480V	CAP. INTERRUPTIVA: ESPACIOS:	JSKAIC 8	ALIMENTACION INFERIOR TIPO DE CAJ/NEMA-1
TABLERO	PROTECCION	A VA B C	ALIMENTACION
TAA-PB	400A/3P	132740.09	132740.09 -
TAA-PA	600A/3P	13676.00	13676 -
CH-1	200A/3P	14770.00	14770 -
CH-2	200A/3P	14770.00	14770 -
CH-3	200A/3P	14770.00	14770 -
		0	-
		0	-
		0	-
ALIMENTADOR	150726.09	150726.09	150726.09
3-1/C#		0.80	COEF. DE DEMANDA
1-1/C#	152580.87	152580.87	152580.87
1-1/C#	550.83	550.83	550.83
1-T-Ø		1.25	AMP DEMANDADOS
			FACTOR DE SEGURIDAD
PROTECCION 600A/3P	688.54	688.54	688.54
			AMPERIOS

[illegible]

NOMBRE: TN-7		CAP. INTERRUPTIVA:		2KCAIC	AUMENTACION: INFERIOR	
BARRAS: 12SA				ESPACIO: 5	TIPO DE CAJA: NEMA-1	
VOLTAJE: 277/480V						
TABLERO	PROTECCION	VA			ALIMENTACION	
		A	B	C		
TUN-1	50A/3P	5500	5500	5500	4-1/C-#8 THHN CU + 1-1/C-#10 -1T-1"Ø EMT	
TTN-1	40A/3P	5400	5400	5000	4-1-C-#10 THHN CU + 1-1/C- #10 -1T-4"Ø EMT	
ALIMENTADOR		10900.00	10900.00	10520.00	TOTALES	
3-1/C#			0.80		COEF. DE DEMANDA	
1-1/C#		8720.00	8720.00	8400.00	VA DEMANDADOS	
1-1/C#		31.48	31.48	30.32	ANEX DEMANDADOS	
1T- 1"			1.25		FACTOR DE SEGURIDAD	
PROTECCION		39.35	39.35	37.51	AMPERIOS	
60A/3P						

OMBRE: TUE-5		CAP. INTERRUPTOR: 22KAIC			ALIMENTACI INFERIOR	
BARRAS: 200A		ESPACIOS: 5			TIPO DE CAU/ NEMA-1	
VOLTAJE: 120/208V						
TERMINAL	PROTECCION	VA			ALIMENTACION	
		A	B	C		
1	80A/3P	6000	6200	6200	4-1/C-#4 THHN CU + 1-1/C-#8 - 1-1-1-1/4" EMT	
1	60A/3P	5200	5200	5200	4-1/C-#6 THHN CU + 1-1/C-#10 - 1-1-1-1/4" EMT	
ALIMENTADOR		11200.00	11400.00	11400.00	TOTALES	
3-1/C			0.80		COEF. DE DEMANDA	
1-1/C		8960.00	9120.00	9120.00	VA DEMANDADOS	
1-1/C		74.67	76.00	76.00	AMP DEMANDADOS	
1T-1P			1.25		FACTOR DE SEGURIDAD	
PROTECCION		93.33	95.00	95.00	AMPERIOS	
125A/3P						

FORMS: TUE-6		CAP. INTERRUPTIVA:		22KAIC	ALIMENTACI INFERIOR	
BARRAS: 200A		ESPACIOS:		5	TIPO DE CCAI/ NEMA-1	
OLTJE: 120/208V						
BLERO		VA			ALIMENTACION	
PROTECCION		A	B	C		
1	80A/3P	6000	6200	6200	4-1/C-#THH CU-1-1-1/C-#B-1T-1-1-1/4"Ø EMT	
1	60A/3P	\$200	\$200	\$200	4-1/C-#B THH CU-1-1-1/C-#B-1T-1-1"Ø EMT	
ALIMENTADOR		11200.00	11400.00	11400.00	TOTALES	
3-1/C/			0.80		COEF. DE DEMANDAS	
1-1/C/		8960.00	9120.00	9120.00	VA DEMANDAS	
1-1/C/		74.67	76.00	76.00	ANP DEMANDAS	
1T- 1Ø			1.25		FACTOR DE SEGURIDAD	
PROTECCION		93.83	95.00	95.00	AMPERIOS	
125A/3P						

S/E

REVISION:
ARQ. OLMEDO GOMEZ

REVISION:
SERTA

DESARROLLO:
SERTA

FECHA:
2012

PROYECTO No.