

[illegible]

NOMBRE: TAA-7 BARRAS: 100A VOITAJE: 277/480V		CAP. INTERRUPTIVA: 22KAIC ESPACIOS: 4		ALIMENTACION: INFERIOR TIPO DE CAJA: NEMA-1	
TABLERO	PROTECCION	VA			ALIMENTACION
		A	B	C	
UMA-13	20A/3P	2486.67	2486.67	2486.67	3-1/2-4B THHN CU + 1-1/2-#10- 1T-1"Ø
UMA-18	20A/3P	2486.67	2486.67	2486.67	3-1/2-4B THHN CU + 1-1/2-#10- 1T-1"Ø
		0	0	0	
		0	0	0	
		0	0	0	
		0	0	0	
ALIMENTADOR		4973.34	4973.34	4973.34	TOTALES
	3-1/CP		1.00		CÓD. DE DEMANDA
	1-1/CP	4973.34	4973.34	4973.34	VA DEMANDADOS
	1-1/CI	17.95	17.95	17.95	AMP DEMANDADOS
	1T-1"Ø		1.25		FACTOR DE SEGURIDAD
PROTECCION		22.44	22.44	22.44	AMPERIOS
	40A/3P				

[illegible]

NOMBRE: TTN-7 BARRAS: 125A VOLTAJE: 277/480V		CAP. INTERRUPTIVA: 22KAIC ESPACIOS: 5		ALIMENTACION: INFERIOR TIPO DE CAJA: NEMA-1	
TABlero	PROTECCION	VA A B C			ALIMENTACION
TTN-1	50A/3P	5000	5000	5000	4-1/2" 88 THHN CU + 1-1/2" #10 - 1T-1" Ø EMT
TTN-1	40A/3P	5400	5400	5000	4-1/2" 88 THHN CU + 1-1/2" #10 - 1T-3/4" Ø EMT
ALIMENTADOR		10000.00	10900.00	10500.00	TOTALES
3-1/8"			0.80		COEF. DE DEMANDA
1-1/2"		8782.00	8782.00	8400.00	VA DEMANDADOS
1-1/2"	31.48	31.48	30.32		AMP DEMANDADOS
1T-Ø			1.25		FACTOR DE SEGURIDAD
PROTECCION		39.35	39.35	37.91	AMPERIOS
	60A/3P				

NOMBRE: TUE-6		CAP. INTERRUPTOR:		22KAIC		ALIMENTACIÓN INFERIOR	
BARRAS: 200A		ESPACIOS:		5		TIPO DE CAJ/ NEMA-1	
VOLTAGE: 120/208V							
TITULO	PROTECCION	VA					
		A	B	C			
TUT-1	85A/3P	6000	6200	5200	4-1/4"X 3/4" THHN CU + 1-1/4"X #8 - 1T- 1/4"Ø EMT		
TTE-1	60A/3P	5200	5200	5200	4-1/4"X #8 THHN CU + 1-1/4"X #10 - 1T- 1/4"Ø EMT		
ALIMENTADOR		11200.0	11 400.0	11 400.0			TOTALES
3-1/8"			0.80				COEF. DE DEMANDA
1-1/8"		8960.0	9120.0	9120.0			VA DEMANDADAS
1-1/8"		74.67	76.00	76.00			AMP DEMANDADAS
1T- Ø"			1.25				FACTOR DE SEGURIDAD
PROTECCION		93.33	95.00	95.00			AMPERIOS
125A/3P							

DE